

**To:** Fergal Hegarty[fergal.hegarty@actionrenewables.co.uk]; Tom Forgrave[tom.forgrave@Personal information redacted by the RHI Inquiry]  
**From:** RHI Accreditations  
**Sent:** 2014-10-07T14:52:32Z  
**Importance:** Normal  
**Subject:** TM - Further Information Request CRM:0053887  
**Received:** 2014-10-07T14:52:33Z

Dear Tom/Fergal,

In order to progress the six RHI applications that you currently have in progress could you please confirm the following information:

- Is the table below an accurate summary of the heat uses served by the RHI applications?
- Do RHI Personal information redacted by the RHI Inquiry and RHI Personal information redacted by the RHI Inquiry both serve Poultry House 3? If so, can you confirm that the heating units within this poultry house are hydraulically separate?

NIRHI	Installation Name	Comments
<small>Personal information redacted by the RHI Inquiry</small>	Poultry House 1	Final schematic shows installation is heating poultry house 1.
<small>Personal information redacted by the RHI Inquiry</small>	Poultry House 6	Final schematic shows installation is heating poultry house 6 only but pipework passes through poultry house 5.
<small>Personal information redacted by the RHI Inquiry</small>	Poultry House No 1, No 2 & Dwelling	Schematic shows installation is providing heat to <b>poultry houses 3</b> and 5.
<small>Personal information redacted by the RHI Inquiry</small>	Poultry House 2	Schematic shows installation is providing heat to poultry house 2.
<small>Personal information redacted by the RHI Inquiry</small>	Poultry House 3	Schematic shows installation is heating <b>poultry house 3</b> only but pipework passes through poultry house 4.
<small>Personal information redacted by the RHI Inquiry</small>	Poultry House 4 and dwelling house	Schematic shows installation is heating poultry house 4 and 'dwelling house'.

Please can you reply to this email with clarification regarding the questions above. We will then hopefully be in a position to move forward with approval of the applications.

Kind regards,

Tommy

**Tommy Moody**

Technical Manager, RHI

Non-Domestic RHI

9 Millbank

London

SW1P 3GE

[www.ofgem.gov.uk](http://www.ofgem.gov.uk)