

Viessmann Vitoligno 300-P Commissioning Certificate

Customer Details Name <u>STEPHEN BRIMSTONE</u> Address Personal information redacted by the RHI Inquiry [Redacted]	Boiler type:- Viessmann Boiler Model:- Vitoligno 300-P (12Kw), (18Kw), (24Kw), (30Kw), (40Kw), (48Kw) Boiler Serial No:- <u>750228550101102</u> Feed System <u>(a) Auger</u> , (b) Suction, (c) Auger/Vacuum Fuel Type at time of Commissioning:- <u>PELLET</u> Date Commissioned:- <u>6/8/15</u> Chimney Plate Installed? Yes <input checked="" type="checkbox"/>
Installation Address if Different from above Name _____ Address _____ _____ _____ _____	

Domestic Install / Commercial Install

Boiler has been commissioned by Terence Cassidy of
 C2 Energy Ltd,
 2 Tullyverry Drive,
 Greysteel,
 Co. Derry,
 BT47 3YG

Hydraulic Diagram completed on CAD? Yes / No
 Any Key features requested by Customers: Yes / No RETAIN EXISTING FEED AUGER

- (a) Pellets provide 4.8Kw of energy per 1Kg
- (b) Boiler Output 32 kW
- (c) Fuel used per hour (b) / (a) = 6.67 kg
- (d) Expected Average Annual Running Hours 1500
- (e) Fuel Used per year (c) * (d) 10 TON
- (f) Fuel cost per Kg = £ 0.21 per 1 Ton / 1000
- (g) Annual Fuel cost = (f) * (e) £2100

C2 Energy Ltd are members of the RECC (Renewable Energy Consumer Code) & Also members of the MCS (Microgeneration Scheme)
 Boiler is commissioned and warranty begins. Boiler Must be serviced every 2000Hrs of Operation or Annually whichever falls first. Warranty is only valid with regular C2 Energy Ltd service and Customer Routine maintenance as per service manual