

Internal Only

----- Original Message -----

From: RHI Accreditations

Received: 07/09/2015 13:07

To: Stephen Brimstone

Subject: SAS [redacted] - Further information CRM:0208168

RHI Number	[redacted]	Account Name	Stephen Brimstone
Applicant Name	Stephen Brimstone	Technology	Solid Biomass Boiler

Dear Stephen Brimstone

Thank you for your application for accreditation to the Non-Domestic Renewable Heat Incentive (RHI) Scheme. I am currently reviewing your application and require the following information to assess the eligibility of your installation:

- The Commissioning Date on the Commissioning Certificate does not match the application/MCS Certificate. Can you please provide an explanation for the difference in dates in HH120?

- Can you please ensure that the Postcode of the installation address is on the Commissioning Certificate?

- Can you please provide internal and external photos of the workshop area to accompany the Non-Domestic Questions?

- Can you please ensure that the building boundaries are on the Schematic Diagram?

HK110 - The boiler serial number listed here does not match that on the boiler name plate. Please ensure the correct serial number is consistent across all documents and HK110.

HI120a-1 - Please confirm that meters have been sized appropriately so that they are generally operating above the transition flow value, and provide evidence that they are appropriate for the temperature of the liquid for which they are metering, such as a photo of the flow meter.

- You have stated in HH110 that heat is used in a different building from the biomass boiler and that there is external pipe work. therefore, can you please complete the attached Heat Loss

Internal Only